

RECOMMENDED MINIMUM CLEARANCES ARE AS FOLLOWS:

- ·CONTROL END (FRONT) TO WALL 1.0 M.
- ·T□P-0.6 M.
- TUBE CLEANING = 1500MM
- ·MINIMUM BELT LENGTH (EACH LEG)= 2600MM (8.5 FEET)
 ·WATER CONECTIONS FOR CONDENSER & COOLER:VICTAULIC JOINT (FOR SIZES REFER TABLE)(SUITABLE TO NATIONAL RIGID COUPLING STYLE 5
- ·BACKSIDE TO WALL (COOLER WATER CONN)= 1.0 M
- POINT LOAD EQUALLY DISTRIBUTED ON A, B, C & D.
- ALL DIMENSIONS ARE SUBJECT TO CHANGE DUE TO CONTINUOUS IMPROVEMENT.

							-NTS				⊕ €
						Å	BLUE STAR		GENERAL ARRANGEMENT XWC2VS-013AR3		
							DATE	NAME	A W CE V 3 OTOHING		
							Sep-22-20	NBC	DRAV	/ING No. SHT 1 DF	⊥ REV
						CHD	Sep-22-20	PDD/SSG	GA-XWC	2VS-013AR3	
RE∨	DATE	ENGINEERING CHANGE	C.N.No.	DRN	CHD	APPD	Sep-22-20	AZB			